


# Revised Discharge Standards and the Challenge of Treating Increasing Sewage Volumes



**Asit Nema** B.Engg. (Civil), M.Tech. (IIT Kanpur, 1985), M.Sc. (Netherlands, 1993)



Formerly with Indian Engg. Services, 1985

**Foundation for Greentech Environmental Systems**

**D-208 Sarita Vihar**

**New Delhi 110 076**

# Structure of the presentation

- 
- 
- Introduction
  - Background
  - Countrywide status of sewage treatment
  - Capacity created under NRCP
  - Status of the metros
  - Diverse issues affecting sewage discharges
  - Discharge standards for STPs – national and international
  - Diverse schools of thought.
  - An alternate paradigm.

# Introduction



- Current status re sewage treatment capacity and discharge norms.
- The presentation is neither a critique nor a prescription.
- It is experience sharing, bringing out issue and highlighting challenges.

# Background

- Okhla Sewage Treatment Plant, 1937!
- Water (Prevention and Control of Pollution) Act, 1974
  - Min. National Standards (MINAS) as recommendations from CPCB to SPCBs.
- Ganga Project Directorate, 1984
  - Ganga Action Plan, 1985
  - Yamuna Action Plan, 1993
- The Environment (Protection) Act, 1986
- The Environment (Protection) Rules, 1986
  - General Standards, 1988
  - General Standards in 1993 (+ / - few parameters).
  - Revised standards for selected parameters, 2017.

# Country wide inventory of STPs

Particulars		Total
Existing STPs across the country		695
- Operational STPs	615	
- Non-operational STPs	80	
STPs under construction		154
STPs under planning		71
<b>Total</b>		<b>920</b>
Compliance with discharge quality		~ 40%

Source: CPCB, 2015

# Countrywide status of sewage generation & treatment

	2004-5	2014-15
Sewage generation	38,250	62,000
Installed STP capacity	12,000	23,500
% installed capacity	~ 30%	~ 38%

- Capacity utilisation of existing STP : ~ 30%
- Actual sewage treated (2015) : ~ 7,000 mld (11% of total generation)
- STPs' discharge compliance: ~ 40%.
- Untreated sewage discharge: ~ 55,000 mld (89% of total generation)



# Countrywide status of sewage generation & treatment

- MH, TN, UP, NCT Delhi & Guj (5/36) account for:
  - ~ 50% of total generation in the country, and
  - ~ 67% of the total installed STP capacity.
- 7 states/UTs without an STP:
  - Chhattisgarh, Daman & Diu, Assam, Tripura, Arunachal Pradesh and Nagaland.
- Only HP & Sikkim and Chandigarh (UT) have adequate STP capacity to deal with present sewage volume.



# Capacity created under River Action Plans

## ➤ Ganga Action Plan Ph-I

- States : UP (UK), Bihar (JH) and WB
- Number of towns: 25
- Original estimated flow: 1340 mld
- **Number of STPs: 34**
- **Aggregate STP capacity: 870 mld**
- Cost (1994) : Rs. 462 Crore

## ➤ Yamuna Action Plan

- States: Haryana, UP (and Delhi)
- **Number of STPs: 42**
- **Aggregate STP capacity: 732 mld**
- Cost (1993-2003) : Rs. 676 Crore

## ➤ National River Action Plan (excluding GAP & YAP)

- 14 states (AP, Tel, JH, Guj, Goa, KR, MH, MP, Odisha, Punjab, TN, Kerala, Sikkim and Nagaland)
- Number of towns: 75
- Number of river stretches: 31
- **Aggregate STP capacity created : 2,446 mld**



# STP capacity in Metro Cities

- Status in the 65 metro and capital cities (more than 10 Lac Population).
  - Sewage generation : ~ 15,644 mld
  - STP capacity : ~ 8,040 mld
  - Coverage : ~ 51%.
- Delhi & Mumbai : 55% of the total metro capacity.
- Remaining 63 cities account for the balance 45% capacity.
- In most of these cities > 50% of the sewage is discharged untreated.

# Sewage treatment capacity in Delhi

- Number of STPs : 36
- Sewage generation : 4155 mld
- Aggregate installed capacity: 3110 mld
- Operational capacity: 2755 mld
- Sewage collected and treated : 2065 mld (50% of generation)
- **Untreated sewage discharged into river Yamuna: 2090 mld (50%)**
- **STP capacity utilization: 66%**

- 318 mld STP to be commissioned in 2019.
- 564 mld STP is planned at Okhla.
- Over 150 decentralized STPs (1-4 mld) are planned all across NCT for rural settlements.

## Discharge norms in Delhi

	Norms	Capex /mld
1 <sup>st</sup> generation	30 : 50	
2 <sup>nd</sup> generation	20 : 30	0.9 Cr
3 <sup>rd</sup> generation	10 : 10; $N_{\text{tot}} < 10\text{mg/l}$ $P < 2\text{ mg/l}$	1.8 Cr.



# Yamuna in Delhi





# STP capacity in Kolkata

- Number of STPs : 5
- Sewage generation : ~ 2200 mld
- Aggregate installed capacity: ~ 180 mld
- Sewage collected and treated : ~ 170 mld (~100 % of generation)
- Untreated sewage discharged into East Kolkata Wetland System: 2030 mld (+90%)



# STP capacity in Mumbai

- Sewage generation: ~ 2700 mld
- Number of existing STPs: 7
  - Installed capacity: 2130 mld
  - Mainly primary treatment
- Present collection and Tr. : 1384 mld (~50%)
- Untreated discharge: ~ 1300 mld (~50%)
- Proposed new STPs: 7
  - Aggregate capacity: ~ 1700 mld
  - Secondary and tertiary treatment for Re-N-Re!





# STP capacity in Chennai

- Sewage generation: ~ 1800 mld
- Number of existing STPs: 12
  - Installed capacity: 764 mld
- Present collection and Tr. : 550 mld (~ 30%)
  - 36 mld treated sewage Re-N-Re in industries.
- Untreated discharge: ~ 1250 mld (~70%)



# Diverse issues affecting sewage treatment

- Non-existent or partial sewerage systems.
    - Limitations of trunk sewers.
    - Arbitrary diversions to open drains.
  - Weak enforcement for house connection.
  - Inadequate conveyance system.
    - Inadequate pumping capacity.
    - Inoperative pumping machinery.
    - Inadequate back up capacity.
    - Unwillingness to operate generators.
  - Lack of funds with ULBs for :
    - O&M of Sewage pumping stations.
    - O&M of STPs.
    - Replacement of worn-out equipment
  - Limited technical expertise for operation.
  - Rapid deterioration of plant and equipment.
  - Lack of MIS and supervision.
- **Lack of robust and systemic approach for continuous monitoring and evaluation at the program level.**
  - **Inconsistent paradigms of (1) resource and energy recovery coupled with (2) cost, energy and footprint minimization.**
  - **Lack of inputs towards capacity building.**







# Revised STP discharge standards

Parameter	General standards (1993-2015) for discharge of effluent		Draft standards for new STPs (2015)	Final standards (2017)	EU	China
	Water bodies	Land				
pH	6.5 – 9.0	6.5 – 9.0	6.5 – 9.0	6.5 – 9.0	NA	6-9
BOD (mg/l)	30 3d@ 27°C	100 3d@ 27°C	10 3d@ 27°C	20\$ / 30 3d@ 27°C	25 5d@ 20°C	30 5d@ 20°C
COD (mg/l)	250	NS	50	250	125	100
TSS (mg/l)	100	200	20	50\$ / 100	35 <sup>a</sup> / 60 <sup>b</sup>	30
NH4-N (mg/l, N)	50	NS	5	NS (50) <sup>#</sup>		
TKj-N (mg/l, N)	82 (100 as NH <sub>3</sub> )	NS	NS	NS (82) <sup>#</sup>		
Nitrate-N (mg/l, N)	10	NS	NS	NS (10) <sup>#</sup>		
Total-N (mg/l, N)	NS (~ 92)	NS	10	NS (~ 92) <sup>#</sup>	10 <sup>c</sup> / 15 <sup>d</sup>	
Phosp. (mg/l, P)	5 <sup>^</sup>	NS	NS	NS (5) <sup>#</sup>	1 <sup>c</sup> / 2 <sup>d</sup> €	3
Faecal Coliform (MPN/100 ml)						
- Desirable	1000 <sup>*</sup>		< 100	< 1000		10,000 <sup>¥</sup>
- Max perm.	10,000 <sup>*</sup>					

\$: Metro and state capitals  
 ^: Dissolved Phosphorus  
 #: Min. National Standards

\*: Recommended under NRCP.  
 ¥: Total coliform

a: > 10,000 PE      b: 2,000-10,000 PE  
 c: > 100,000 PE      d: 10,000-100,000 PE  
 €: Total (dissolved + suspended)

# WWTP effluent thresholds, EU Directive 91/271/EEC

Parameter	Unit	Maximum concentration	Remarks
Biochemical oxygen demand (BOD <sub>5</sub> )	mg/l O <sub>2</sub>	25	Without nitrification
Chemical oxygen demand (COD)	mg/l O <sub>2</sub>	125	
Total suspended solids (TSS)	mg/l	35	60 (Discharge < 10,000 PE)
Total phosphorus (P <sub>tot.</sub> )	mg/l P	2	1 (Discharge > 100,000 PE)
Total nitrogen (N <sub>tot.</sub> )	mg/l N	15	10 (Discharge > 100,000 PE)

COD : BOD ratio = 5

# German Wastewater Directive (AbwV)

Sample according to size of WWTP	Population Eq.	COD	BOD <sub>5</sub>	NH <sub>4</sub> -N	Total Nitrogen (as N)	Total Phosphorous (as P)
Class 1: < 60 kg/d BOD <sub>5</sub> (raw)	1,000	150	40	-	-	-
Class 2: 60 to 300 kg/d BOD <sub>5</sub> (raw)	1,000-5,000	110	25	-	-	-
Class 3: 300 to 600 kg/d BOD <sub>5</sub> (raw)	5,000-10,000	90	20	10	-	-
Class 4: 600 to 6,000 kg/d BOD <sub>5</sub> (raw)	10,000-100,000	90	20	10	18	2
Class 5: 6,000 kg/d BOD <sub>5</sub> (raw)	100,000	75	15	10	12	1

Note.

1. Qualified sample or 2 h mixed sample.
2. No specification for N and P for smaller plants.

COD : BOD ratio = 3.75 - 5

# Indian revised standards – few observations

- Uniform standards for discharge into water bodies or on land for irrigation.
- Uniform standards for plants/ ULBs of all sizes.
  - 30:100 remains for all non-metro cities.
- MINAS apply for all other parameters not specified in the Oct 2017 Notification.
- Do not specify nature and duration of samples; permissible violations in a month/year.
- Apparent resistance in lowering of standard for COD
  - COD: BOD ratio is between 8 – 12.5
- The challenges of nitrogenous oxygen demand and phosphorus are yet to get consideration.
- Correlation between Total-Nitrogen and Faecal Coliform is yet to be addressed.

# Diverse schools of thought

- Full treatment in one go - effluent quality at par with the best.
  - Energy and resource recovery.
  - Minimalist approach:
    - Minimising foot print.
    - Minimising energy requirement.
    - Minimising capital and operating costs.
  - Water resources diversion for productive uses.
  - Ecological discharge in rivers.
  - Zero discharge from STPs.
- Lessons from the past
    - There are no easy solutions.
    - Resources are limited.
    - Slow speed in capacity creation
      - Last 30 years - average capacity @ 750 mld/annum.

# An alternate paradigm

- Can we keep things simple – practicable and affordable?
- Wider geographical coverage over the watershed/ river basin versus few plants producing high effluent quality.
- To start with, aim for moderate effluent quality.
- Plant upgradation in stages to achieve higher effluent quality.
  - Phase-I: Enhanced Primary Treatment.
  - Phase-II: Secondary Treatment.
  - Phase-III: Tertiary Treatment.



# Comparative organic load reduction assessment

Particulars	Unit	Conventional approach	Enhanced Primary Treatment approach	Remarks
Sewage quantity	mld	62,000	62,000	
Quantity being treated	mld	7,000	43,400	11% v/s 70%
Raw BOD	mg/l	200	200	
Final BOD	mg/l	30	50	75% reduction
BOD reduction	mg/l	170	150	
<b>BOD load reduced</b>	<b>Tonnes/day</b>	<b>1,190</b>	<b>6,510</b>	
<b>BOD load discharged</b>	<b>Tonnes/day</b>	<b>11,210</b>	<b>5,890</b>	



**Thank you very much**

